

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20173427, Building Permit - Residential

Address: 1349 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sidewalk Inspection	Jeremy Young	Partial	Wednesday, June 27, 2018

Informational

- 1 Jeremy Young 06/27/2018 2:14 PM Contractor has sufficient compacted rock. the cross slope is less than 2% which meets ADA requirements.

Driveway Inspection	Jeremy Young	Partial	Wednesday, June 27, 2018
---------------------	--------------	---------	-----------------------------

Informational

- 1 Jeremy Young 06/27/2018 2:17 PM Contractor has torn out the drive approach. They have less than 2% cross slope which meets ADA compliance. They have the expansion joint and will add it.

Comments: