

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181586, Building Permit - Residential
Address: 1312 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Khanh Nguyen	Failed	Thursday, June 28, 2018

Corrective Action Required

1	Misc	THE PIER AT NE BASEMENT CORNER SHALL BE 4'X4'X16" DEEP
---	------	--

****OK TO POUR THE REST OF THE FOOTING**

Comments: