

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20180217, Building Permit - Residential

Address: 1300 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sidewalk Inspection	Jeremy Young	Passed	Thursday, June 28, 2018

Informational

- 1 Jeremy Young 06/28/2018 10:33 AM Contractor did not call in the pre inspection for the sidewalk. It appears there is sufficient compacted rock below the concrete. The sidewalk meets the less than 2% ADA compliance for cross slope. The ADA ramp is within compliance. There is a 5' turn around pad at the top of the ramp.

Comments:
