

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20180430, Building Permit - Commercial

Address: 2751 NE DOUGLAS ST, Unit:W, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	Khanh Nguyen	Failed	Thursday, June 28, 2018

Corrective Action Required

1	Misc	-CONNECT GEC TO SERVICE GROUNDED CONDUCTOR PER 250.24
---	------	---

**Comments:**