
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20173802, Public Works Infrastructure Permit - Commercial

Residences at Echelon

Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Water Line - Coliform Test 2 Informational	John DiMauro	Partial	Monday, July 02, 2018
1	We collected and delivered the day 2 samples for the water line A.		
DEI-Water Line - Coliform Test 1 Informational	John DiMauro	Failed	Monday, July 02, 2018
1	John DiMauro 06/26/2018 4:01 PM		
	The KAT Excavation crew and I collected water samples for the public and private lines on this project. I delivered the samples to Blue Valley Labs and we will know the results for the day 1 samples tomorrow.		
Informational			
2	The day 1 samples for the water line B and the domestic water line failed.		
DEI-Water Line - Coliform Test 2 Informational	John DiMauro	Failed	Monday, July 02, 2018
1	We collected and delivered the day 2 samples for the water line A.		
Informational			
2	The day 2 samples for the water line A failed.		

Comments:

