

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20180430, Building Permit - Commercial

Address: 2751 NE DOUGLAS ST, Unit:W, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	Khanh Nguyen	Passed	Monday, July 02, 2018

Comments: SCREW BOTH FLANGES TOP AND BOTTOM OF LOWER TIER STUDS. THEN OK TO HANG 1ST LAYER GWB AT 3HR WALL.