

Temporary Certificate of Occupancy

Permit #: PRCOM20181511
Address: 3680 NE AKIN DR, Unit:136, LEES SUMMIT, MO 64064
Inspected On: Monday, July 02, 2018
Inspected By: John BornsMichael Weissenbach
Expiration Date: 7/12/2018 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Monday, July 02, 2018

Corrective Action Required:

1	Misc	OPEN J-BOX ABOVE UTILITY CLOSET. INSTALL BOX EXTENSION IF BOX FILL REQUIRES. CLOSE BOX.
---	------	---

Corrective Action Required:

2	Misc	SEAL JANITOR SINK TO WALL AND FLOOR
---	------	-------------------------------------

Corrective Action Required:

3	Misc	ELECT RECEPT NEAR JAN SINK MUST BE GFCI PROTECTED
---	------	---

Corrective Action Required:

4	Misc	VERTICAL GRAB BARS MUST BE 39" TO 41" FROM REAR WALL TO CENTER AND 39" TO 41" FROM FLOOR TO CENTER OF BOTTOM.
---	------	---

Corrective Action Required:

5	Misc	ANSI 603.3 MOUNTING OF MIRRORS AT ACCESSIBLE RESTROOMS: SET BOTTOM OF VIEWING SURFACE <= 40" AFF
---	------	---

Corrective Action Required:

6	Misc	ACCESSIBLE RESTROOMS MUST HAVE "ACCESSIBLE" SIGNS
---	------	---

Corrective Action Required:

7	Misc	NEC 600.3 UL LISTING OF EXTERIOR LIGHTED SIGNS / DECORATIVE ELEMENTS: IF INTERNALLY LIGHTED, MUST BE UL SHOP-LABELED AS INDICATION OF LISTING.
---	------	--

**Occupancy Inspection -
Fire**

Michael
Weissenbach

Passed

Monday, July 02,
2018