



**LEE'S SUMMIT**  
**MISSOURI**



---

**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20181496	Date:	July 03, 2018
Project Title:	SAINT LUKES SURGICENTER - ALTERATIONS	Applicant:	
Location:	120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086	R F FISHER ELECTRIC COMPANY LLC PO BOX 3110 KANSAS CITY, KS 66103	
Type of Work:		Primary:	(913) 384-1500
Occupancy Group:	I-2		
Description:	ALTERATIONS TO EXISTING SURGICENTER - INCLUDES CONSTRUCTION OF NEW GI PROCEDURE ROOM AND EXPANDING WAITING AREA		
Construction Type:	Type IA		
Map Page:	175X		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(information purposes)

Acceptance testing of the modifications done to the fire alarm system will be required prior to the final occupancy inspection. Contact the fire department to schedule testing. (816)969-1300

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**