

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20173801, Public Works Infrastructure Permit - Commercial

Residences at Echelon

Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Public Curb Inspection	John DiMauro	Partial	Tuesday, July 03, 2018

Informational

1 John DiMauro 07/03/2018 2:09 PM

Crews are on site continuing the install of the curb along Cheddington Dr. I verified mix type and the curb appears to match the plans. They are grouting the back of the curb areas with honeycomb.

DEI-Driveway Inspection	John DiMauro	Partial	Tuesday, July 03, 2018
-------------------------	--------------	---------	------------------------

Informational

1 John DiMauro 07/03/2018 2:06 PM

The crews on site installed the north drive approach for the Arvest bank parking lot that connects to Cheddington Dr. There was sufficient compacted aggregate sub grade. I will return for further inspection after the concrete has cured.

Comments: