

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20182059, Building Permit - Residential

Address: 1328 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Lawn Sprinkler Final</b>	Khanh Nguyen	Passed	Thursday, July 05, 2018

**Comments: LAWN IRRIGATION SYSTEM INSTALLATION: BACKFLOW PREVENTION DEVICE IN PLACE IN YARD BOX. CLOSE PERMIT.**