

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20162554  
**Address:** 1328 NE BRANDYWINE RD, LEES SUMMIT, MO 64064  
**Inspected On:** Thursday, July 05, 2018  
**Inspected By:** John Borns  
**Expiration Date:** 7/26/2018 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	John Borns	Temporary C of O	Thursday, July 05, 2018

**Corrective Action Required:**

1	Misc	-EXPOSE THE SEWER TRACER WIRE ACCESS BOX -MOVE THE AC DISCONNECT TO LOCATION THAT ALLOWS PROPER WORKING CLEARANCE
---	------	---