

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20180570, Building Permit - Residential

Address: 1621 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Tom Chandler	Passed	Thursday, July 05, 2018

Informational

- 1 Tom Chandler 07/05/2018 11:13 AM Driveway has been completed and passed final inspection.

DEI-Sidewalk Inspection	Tom Chandler	Failed	Thursday, July 05, 2018
-------------------------	--------------	--------	----------------------------

Corrective Action Required

- 1 The sidewalk does not meet ADA guidelines.
Tom Chandler 07/05/2018 11:20 AM Sidewalk that was poured on the east side of the driveway meets the ADA requirements. The ADA transition, landing and ramps do not meet ADA requirements.

Comments: