

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20174064, Public Works Infrastructure Permit - Commercial  
COLEMAN EQUIPMENT

Address: 4101 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Grading/Excavation/Fill Inspection Informational	Steve Robbins	Partial	Thursday, July 05, 2018
1	The grading for the road and parking lot has been going on. I spoke with Ed about the set of plans that we have , the plans show an option of not putting down MO-type 5 if they use 9" of portland tilled in the dirt. Our specs call for 6" of Mo-type 5 and 7.5 of base asphalt and 2 of surface. I gave him our spec and let him know our set of stamped plans were not right and did not excuse that is has to be done by Steve Robbins 07/05/2018 11:55 AMour spec.		

Comments: