

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20181348, Building Permit - Commercial

Address: 699 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Not Ready	Friday, July 06, 2018

Corrective Action Required

1	Misc	IPC 305.8; IRC P2603 PROTECTION FROM PENETRATION OF PVC / ABS / PEX / COPPER PLUMBING PIPE LESS THAN 1-1/2" FROM FACE OF FRAMING TO RECEIVE SCREWED OR NAILED COVERING: SHIELD PLATES SHALL EXTEND A MINIMUM OF 2" ABOVE BASE PLATES / TRACKS AND BELOW TOP PLATES / TRACKS (USE "BOCA" PLATES). CHECK ALL.
---	------	---

Partial Correction

2	Misc	CURVED BULKHEAD OK TO COVER
---	------	-----------------------------

Corrective Action Required

3	Misc	IBC 109.1, 109.5; IRC R109.3 INSPECTION ACCESS: PROPERTY LOCKED; INTERIOR NOT ACCESSIBLE. CALL FOR INSPECTION ON DAY WHEN JOBSITE IS ACCESSIBLE.
---	------	---

Comments: