

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20181521, Building Permit - Commercial

Address: 697 NW BLUE PKWY, LEES SUMMIT, MO 64086699 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|-----------------------|
| Gas Service Inspection - Commercial | John Borns | Passed | Monday, July 09, 2018 |
| In-wall Inspection | John Borns | Passed | Monday, July 09, 2018 |
| Gas Piping Inspection - Commercial | John Borns | Partial | Monday, July 09, 2018 |

Corrective Action Required

| | | |
|---|------|--|
| 1 | Misc | ON CLAMP AT ROOFTOP PIPING NEEDS TO BE REPLACED WITH ONE OF CORRECT SIZE |
|---|------|--|

Comments: GAS SERVICE FOR NEW RTU OK FOR USE. DEMISING WALL APPROVED TO COVER.