

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180854, Building Permit - Residential

Address: 4720 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Jason McRoy	Partial	Monday, July 09, 2018

Corrective Action Required

1	Misc	- PRESSURE TEST OK. - gas piping not bonded - will release gas service when bonding is complete
---	------	---

Comments: