

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20180854, Building Permit - Residential

Address: 4720 NE GATEWAY DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Jason McRoy	Partial	Monday, July 09, 2018

### Corrective Action Required

1	Misc	- PRESSURE TEST OK. - gas piping not bonded - will release gas service when bonding is complete
---	------	---

<b>Erosion Control</b>	Jason McRoy	Failed	Monday, July 09, 2018
------------------------	-------------	--------	-----------------------

### Corrective Action Required

1	DCM1 Erosion Control	EROSION CONTROL REQUIRED AROUND THE PERMITER OF LOT. RESTORE EROSION CONTROL ALONG THE STREET  NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE.
---	----------------------	---

**Comments:**