

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180854, Building Permit - Residential

Address: 4720 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Jason McRoy	Passed	Tuesday, July 10, 2018

Corrective Action Required

1	Misc	-SHALL REMOVE ALL LOOSE DIRT FROM BOTTOM OF CORNER PIER
---	------	---

Erosion Control	Jason McRoy	Failed	Tuesday, July 10, 2018
------------------------	-------------	--------	------------------------

Corrective Action Required

1	DCM1 Erosion Control	EROSION CONTROL REQUIRED AROUND THE PERIMETER OF LOT. RESTORE EROSION CONTROL ALONG THE STREET
---	----------------------	---

NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE. AND LOT IS CLEANED UP.

Comments: