



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

July 11, 2018

RACHEL CRAWFORD
6711 NORTHERN AVE
RAYTOWN, MO 64133

Permit No: PRCOM20182123
Project Title: RUSTIC OILS LLC
Project Address: 618 SW 3RD ST, Unit:J, LEES SUMMIT, MO 64063
Parcel Number: 61330168900000000
Location: RNG-31 TWP-47 SEC-06 PT SW 1/4 DAF: BEG AT A PT 1150' W OF SE COR SD SW 1/4 TH N 28' M/L TO N ROW LI OF 3RD ST & TRU POB TH CONT N 220' TH E 130' TO SW COR LOT 58 ROBIN HILLS TH N 125' TO S ROW LI OF
Type of Work: CHANGE OF TENANT
Occupancy Group: MIXED OCCUPANCY
Description: CHANGE OF USE FOR NEW RETAIL STORE (NO CONSTRUCTION)

*drawing is in plan review file

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Approved

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED:(verified at inspection)

Address/suite designation shall be readable from the roadway, front and rear doors.

2. 2012 IFC 906.2- General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED: (verified at inspection)

Provide a minimum of one 2A-10BC fire extinguisher. The extinguisher is to be mounted on a wall close to an exit.

3. Door operations

ACTION REQUIRED:(verified at inspection)

No keyed locks on the egress side of an exit.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.