
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRSUBD20180158, Development - Subdivision
Park Ridge 6th Plat

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Public Curb Inspection	Steve Robbins	Partial	Wednesday, July 11, 2018

Corrective Action Required

- 1 This morning Freedom finish pouring the curbs. I have all the concrete tickets. They are going to come back in the morning and grout some of the storm boxes that have some honey comb. Steve Robbins 07/11/2018 1:49 PM

Comments:
