

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20180434, Building Permit - Commercial

Address: 2751 NE DOUGLAS ST, Unit:X, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, July 12, 2018

Partial Correction

1 Misc

FRAMING FOR 3HR RATED WALL OK FOR 1ST LAYER GWB BOTH FACES; OK TO COVER 1ST LAYER 3/4" GWB BOTH FACES; 2ND LAYER 3/4" GWB BOTH FACES;

FIRESTOPPING IS TO BE DONE USING FIRE CAULK ONLY. NO TAPE & MUD AT GAPS AND PENETRATIONS.

Comments: