

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20180430, Building Permit - Commercial

Address: 2751 NE DOUGLAS ST, Unit:W, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Passed	Friday, July 13, 2018

--

Comments: TWO LAYERS 3/4" GWB BOTH FACES AT RATED WALL OK TO FIRESTOP + TAPE AND MUD. FIRE-CAULK ONLY AT PENETRATIONS AND GAPS -- NO TAPE OR MUD AT LOCATIONS TO BE FIRESTOPPED.