

**PUBLIC WORKS ENGINEERING DIVISION**

## **Inspection Summary**

---

Permit #: PRSITE20180561, Development - Site

TPC Interiors

Address: 1510 SE KINGSPPOINT DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DEI-Water Line - Construction Inspection Informational	John DiMauro	Partial	Friday, July 13, 2018
1	John DiMauro 07/13/2018 2:43 PM		

The plumbing crew installed the riser for the fire line and stubbed it out of the building. I verified material and the kicker poured behind the riser.

**Comments:**

---