

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20181496, Building Permit - Commercial

Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Failed	Monday, July 16, 2018

### Corrective Action Required

1	Misc	NEC 300-11, 330.30 & 334-10 INSTALLATION OF MC ELECTRICAL NOT SECURELY FASTENED WITHIN 12" OF ENTRY TO BOXES [ALLOWABLE EXCEPTION: FIXTURE WHIPS NOT IN EXCESS OF 6' LONG]: SPACE 1E01B
---	------	---

<b>In-wall Inspection</b>	John Borns	Not Ready	Monday, July 16, 2018
---------------------------	------------	-----------	-----------------------

### Partial Correction

1	Misc	OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: 1E01B ; NEW W WALL + IN-FILL AT S WALL EAST;
---	------	---

<b>In-wall Inspection</b>	John Borns	Partial	Monday, July 16, 2018
---------------------------	------------	---------	-----------------------

### Partial Correction

1	Misc	OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: 1E01B ; NEW W WALL + IN-FILL AT S WALL EAST; 1E39A, B,C;
---	------	---

**Comments:**