

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20181560, Building Permit - Commercial

Address: 3510 SW HOLLYWOOD DR, Unit:1, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|--|--------------|----------|------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Footing Inspection - Commercial | John Benisch | Partial | Tuesday, July 17, 2018 |

Partial Correction

1 Misc

OK TO POUR WHEN READY PERIMETER GRADE BEAMS AND
SPREAD FOOTINGS AT LOCATIONS: FROM B.4/A.P CLOCKWISE TO
A.Q/B.7; B.6.8/A.K.4 CLOCKWISE TO B.5.8/A.J;

Comments: