

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20180854, Building Permit - Residential

Address: 4720 NE GATEWAY DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Jason McRoy	Passed	Tuesday, July 17, 2018

<b>Electrical Service Inspection - Residential</b>	Jason McRoy	Passed	Tuesday, July 17, 2018
--	-------------	--------	------------------------

<b>Gas Service Inspection - Residential</b>	Jason McRoy	Failed	Tuesday, July 17, 2018
---	-------------	--------	------------------------

Corrective Action Required

2 Misc - GAS LINE INE IS NOT CONNECTED AT FIRE PLACE

<b>All Rough Inspection - Residential</b>	Jason McRoy	Failed	Tuesday, July 17, 2018
---	-------------	--------	------------------------

Corrective Action Required

2 Misc

- straps at garage portal inside not nailed off completely
- Missing door to patio
- Missing front entry door
- Cantilever floor joists under master open to exterior. siding needed under windows

**Comments:**