



**LEE'S SUMMIT**  
MISSOURI



## **FIRE DEPARTMENT**

### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20181021	Date:	July 18, 2018
Project Title:	LEES SUMMIT MEDICAL CENTER CT	Applicant:	
ADDITION			
Location:	2100 SE BLUE PKWY, LEES SUMMIT, MO 64063	AMERICAN FIRE SPRINKLER CORPORATION	
		PO BOX 958	
		MISSION , KS 66201	
Type of Work:		Primary: (913) 722-6900	
Occupancy Group:	I-2		
Description:	BUILDING ADDITION FOR NEW CT EQUIPMENT AND SUPPORT ROOMS - PERMIT INCLUDES ALTERATION OF EXISTING PHYSICIAN ROOMS INTO FAST TRACK ROOMS		
Construction Type:	Type IB		
Map Page:	196K		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

#### **ACTION REQUIRED:**

The CT addition area will required field testing (hydrostatic pressure test) prior to the final occupancy inspection. Contact the Fire Department to schedule testing. (816)969-1300

2. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

#### **ACTION REQUIRED:(veriiifed at inspection)**

The existing sprinkler riser shall be current with required service and maintenance. The riser shall have a current service tag posted on on the systems riser.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**