

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20172649, Building Permit - Residential

Address: 4801 SW RAINTREE PKWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Jason McRoy	Failed	Friday, July 20, 2018

Corrective Action Required

1	Misc	-INTERIOR DRAINAGE TILE IS RUNNING OVER TOP OF THE PLUMBING IN 2 LOCATIONS
---	------	---

Comments: