

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20172630, Building Permit - Residential

Address: 1337 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Suspended Slab Inspection	John Borns	See comments	Friday, July 20, 2018

**Comments: SUSPENDED SLAB AT FRONT PORCH PREP'ED FOR POUR WITH #4 RE-BAR @ 12" O/C E/W.
NO PRINTS FOUND ON SITE. IF PER PRINT OK TO POUR WHEN READY.**