

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20170715, Building Permit - Residential

Address: 3352 SW JESSIE LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

| Inspection:                                         | Inspector:  | Outcome: | Date:                 |
|-----------------------------------------------------|-------------|----------|-----------------------|
| <b>Occupancy Inspection -<br/>Codes Residential</b> | Jason McRoy | Failed   | Friday, July 20, 2018 |

### Corrective Action Required

|   |      |                                                                                                                                                                                                                    |
|---|------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | -- LOOSE OUTLET AT REFRIGERATOR<br>- LOOSE OUTLET AT MASTER LEFT OF DOOR<br>- WINDOW SCREENS THROUGHOUT<br>- JOIST HANGERS AT UNDER DECK<br>SMOKE ALARM IN GUEST BED HALL IS SMOKE ONLY NEEDS TO BE COMBO SMOKE/CM |
|---|------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

### Comments: