

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20173222, Building Permit - Commercial

Address: 4101 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:

Inspector:

Outcome:

Date:

In-wall Inspection

Khanh Nguyen

Failed

Friday, July 20, 2018

Corrective Action Required

1 Misc

-HAVE ENGINEER ADDRESS NOTCHED UPPER EXTERIOR WALL
GIRT (BY PLUMBING) AT NE SECTION OF BUILDING

-HAVE ENGINEER SPECIFY THE ANCHORING OF THE TALL WALL AT
THE NORTH SIDE OF BUILDING

****OK TO ROCK, EXCEPT THE ABOVE**

Comments: