

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20180434, Building Permit - Commercial

Address: 2751 NE DOUGLAS ST, Unit:X, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Friday, July 20, 2018

Corrective Action Required

1	Misc	-COMPLETE RACEWAY SEAL-OFFS -X1 UNIT GFCI NOT WORKING
---	------	--

Comments: