

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20181063, Building Permit - Residential

Address: 1609 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Residential</b>	Jason McRoy	Passed	Friday, July 20, 2018

<b>Gas Piping Inspection - Residential</b>	Jason McRoy	Passed	Friday, July 20, 2018
--	-------------	--------	-----------------------

<b>All Rough Inspection - Residential</b>	Jason McRoy	Passed	Friday, July 20, 2018
---	-------------	--------	-----------------------

<b>Gas Service Inspection - Residential</b>	Jason McRoy	Failed	Friday, July 20, 2018
---	-------------	--------	-----------------------

Corrective Action Required

1	Misc	- GAS LINE NOT BONDED
---	------	-----------------------

Comments: