

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20182266, Building Permit - Commercial

Address: 664 SE BAYBERRY LN, Unit:102, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Electrical Inspection - Commercial</b>	Khanh Nguyen	Passed	Friday, July 20, 2018

### Comments:

INSIDE "PROVIDENCE" RM ONLY: REPLACED 3 RECEPTACLES WITH HOSPITAL GRADE RECEPTACLES SUPPLIED BY MC CABLES (GREEN MC) COMPLYING WITH NEC 517.13. I WAS ABLE TO VERIFY ONE RECEPTACLE FED BY GREEN MC CABLE. I TALKED TO THE ELECTRICIANS AND WAS ASSURED THAT ALL MC CABLES TO THE 3 RECEPTACLES ARE IN COMPLIANCE WITH 517.13