## **Development Services Department**

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## **Inspection Summary**

## Permit #:PRRES20181069, Building Permit - Residential Address: 1705 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Jason McRoy	Failed	Tuesday, July 24, 2018
All Rough Inspection - Residential	Jason McRoy	Failed	Tuesday, July 24, 2018
Corrective Action Require 1 Misc	ed • • • •	strap/plate at dryer vent Electric panels not labeled Gas line not bonded Gas line has 0 psi Fire stop hole at closet by furnace OK TO INSULATE	
Electrical Service Inspection - Residential	Jason McRoy	Failed	Tuesday, July 24, 2018
Gas Piping Inspection - Residential	Jason McRoy	Failed	Tuesday, July 24, 2018

**Comments:**