

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181829, Building Permit - Residential

Address: 1325 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|---|--------------|----------|------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Footing Inspection - Residential | Khanh Nguyen | Failed | Tuesday, July 24, 2018 |

Corrective Action Required

| | | |
|---|------|-----------------------|
| 1 | Misc | **SEE EROSION CONTROL |
|---|------|-----------------------|

| | | | |
|------------------------|--------------|--------|------------------------|
| Erosion Control | Khanh Nguyen | Failed | Tuesday, July 24, 2018 |
|------------------------|--------------|--------|------------------------|

Corrective Action Required

| | | |
|---|----------------------|---|
| 1 | DCM2 Erosion Control | DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED. |
|---|----------------------|---|

**PROVIDE 3/4" GRAVEL AT LOT ENTRANCE

Comments: