

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20181488, Building Permit - Residential

Address: 4060 NE CHAPEL MANOR DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection - Residential</b>	Khanh Nguyen	Passed	Tuesday, July 24, 2018

<b>Erosion Control</b>	Khanh Nguyen	Failed	Tuesday, July 24, 2018
------------------------	--------------	--------	------------------------

### Corrective Action Required

1	DCM2 Erosion Control	DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED.
---	----------------------	---

### Comments: