

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181168, Building Permit - Residential

Address: 1313 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection - Residential	Khanh Nguyen	Failed	Tuesday, July 24, 2018

Corrective Action Required

1	Misc	-PROVIDE CLEANOUT FOR SEWER PIPE WITH 4 ELBOWS EVERY 40 FT
---	------	--

Comments: