

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20181496, Building Permit - Commercial

Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Khanh Nguyen	Partial	Tuesday, July 24, 2018

Corrective Action Required

1	Misc	**PHASE 1 ONLY** -INSPECTIONS STILL NOT FULLY RESOLVED: RATED WALL ASSY, IN-WALL, AND ABOVE-CEILING INSPECTIONS -FIRE DEPT APPROVAL REQUIRED -OK TO OCCUPY RM 1E01B. NO WORK IN RM 1E29&1E33
---	------	---

Occupancy Inspection - Fire	Michael Weissenbach	Partial	Tuesday, July 24, 2018
--	------------------------	---------	------------------------

Comments: