

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20181348, Building Permit - Commercial

Address: 699 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Wednesday, July 25, 2018

Corrective Action Required

1	Misc	NOT READY FOR ABOVE-CEILING INSPECTION
---	------	--

**FIRE SPRINKLER SYSTEM NOT COMPLETED

**SUPPORT DWV PIPING AT MAX 4 FT INTERVAL

Corrective Action Required

7	Misc	SOME ELECTRICAL BOXES NOT MADE UP AND CLOSED.
---	------	---

**ABOVE PRE-KITCHEN AREA. INSTALL LIGHT FIXTURES

Comments: