



**LEE'S SUMMIT**  
**MISSOURI**



---

**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20173849	Date:	July 25, 2018
Project Title:	TAILOR MADE LANDING	Applicant:	
Location:	1610 SE HAMBLEN RD, LEES SUMMIT, MO 64081	JOHNSON CONTROLS 11019 Strang Line road Lenexa, Kansas 66215	
Type of Work:			
Occupancy Group:	MIX		
Description:	CONVERT BARN TO OFFICE/WAREHOUSE AND ADDITIONAL FUTURE TENANT SPACE	Primary: (816)215-0681	
FOUNDATION PERMIT -	PRCOM20180059		
Construction Type:	Type IIB (Unprotected)		
Map Page:	195R		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

**ACTION REQUIRED:(information purposes)**

Testing of the fire alarm system will be required prior to the final occupancy inspection. Contact the fire department to schedule testing. (816)969-1300

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**