

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20181846, Building Permit - Residential  
Address: 1301 NE GOSHEN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Residential</b>	Khanh Nguyen	Passed	Thursday, July 26, 2018

<b>Erosion Control</b>	Khanh Nguyen	Failed	Thursday, July 26, 2018
------------------------	--------------	--------	-------------------------

### Corrective Action Required

1	DCM2 Erosion Control	DEFICIENT EROSION CONTROL INSTALLATION. EROSION CONTROL REQUIRED AROUND THE WHOLE LOT, INCLUDING THE PILE OF DIRT
		NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED.

### Comments: