

**PUBLIC WORKS ENGINEERING DIVISION**

**Inspection Summary**

Permit #: PRPWFR20171420,  
CREEKSIDE AT RAINTREE

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

| <b>Inspection:</b>     | <b>Inspector:</b> | <b>Outcome:</b> | <b>Date:</b>          |
|------------------------|-------------------|-----------------|-----------------------|
| DEI-Street - Base Lift | John DiMauro      | Passed          | Monday, July 30, 2018 |

Informational

1 John DiMauro 07/28/2018 11:46 AM

Phillips Paving is installing the base lift for the road. I verified the correct mix type and temperature. KC Testing is on site performing the required testing of the asphalt.

|                             |              |         |                       |
|-----------------------------|--------------|---------|-----------------------|
| DEI-Street - Surface Course | John DiMauro | Partial | Monday, July 30, 2018 |
|-----------------------------|--------------|---------|-----------------------|

Informational

1 John DiMauro 07/30/2018 2:57 PM

Phillips Paving installed the surface lift for the road. I verified the asphalt type and temperature. KC Testing was on site and performed the required testing for the asphalt.

**Comments:**