

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161771, Building Permit - Commercial

Address: 819 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Jason McRoy	Passed	Tuesday, July 31, 2018

Partial Correction

1	Misc	PVC CONDUIT TRENCHED/BORED: FROM NEAR DRIVEWAY CURB W OF N END OF BLDG 3 G2, ONE 3/4" TO LOCATION OF MONUMENT SIGN TO BE BUILT @ DONOVAN RD & NW ENTRANCE DRIVE, ONE 3/4" BORED UNDER DRIVEWAY TO L.P. BASE AT W SIDE OF DRIVEWAY; [ONE 3/4" ENTIRE LENGTH OF ISLAND W OF BLDG #7 + ONE 3/4" PART LENGTH -- THEN STUBBED EAST FOR CARPORT TO BE CONSTRUCTED; [BESIDE SIDEWALK ALONG W SIDE OF BLDG #5;
---	------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

7/27-UE FOR SIDEWALK BOLLARD LIGHTS ALONG BUILDING 7, AND SIDEWALK ALONG SOUTH OF BUILDING 6

Comments: