

Temporary Certificate of Occupancy

Permit #: PRRES20173808
Address: 4716 NE POCONO CIR, LEES SUMMIT, MO 64064
Inspected On: Wednesday, August 01, 2018
Inspected By: Mark Harding
Expiration Date: 8/30/2018 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Temporary C of O	Wednesday, August 01, 2018

Corrective Action Required:

1	Misc	-FINAL GRADE, SOD, SPLASHBLOCKS, SUMP PUMP EXTENSION -INSTALL ROOF DRAINAGE SYSTEM -SEAL EXTERIOR: WALL PENETRATIONS, LIGHTS, HOSE BIBB, ETC -EXPOSE WATER METER. LID SHALL BE AT GRADE LEVEL. METER-LID DISTANCE SHALL BE 14"-18" PER STANDARD -SEWER TRACER BOX AND TRACER WIRE SHALL BE ACCESSIBLE AT GRADE LEVEL
---	------	--