

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180715, Building Permit - Residential
Address: 4825 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Mark Harding	Failed	Wednesday, August 01, 2018

Electrical Service Inspection - Residential	Mark Harding	Passed	Wednesday, August 01, 2018
--	--------------	--------	----------------------------

All Rough Inspection - Residential	Mark Harding	Failed	Wednesday, August 01, 2018
---	--------------	--------	----------------------------

Corrective Action Required

1	Misc	- dryer vent not connected in wall. - dryer vent over span -fire stop required areas 16" below ceiling line. not at ceiling line -anchor bsmt and garage beam posts -install garagae wall straps, install 2" washers at west garagae wall plate bolts. -2nd floor heat rund hanging out of ceiling. -install 3 studs per plans at 2x12 ceiling 2nd floor. -joist hanger bsmt joist at stair wall and header.
---	------	--

Comments: