

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20182020, Building Permit - Commercial

Address: 110 NE SAINT LUKES BLVD, Unit:245, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Wednesday, August 01, 2018

Corrective Action Required

1	Misc	RATE WALLS IN 201 AND 202 1 LAYER IN 201 AND 2 LAYERS IN 202
---	------	---

Comments: