

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20180696, Building Permit - Commercial

Address: 201 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Mark Harding	Failed	Thursday, August 02, 2018

Corrective Action Required

1	Misc	INSTALL PLUMBING AS PER APPROVED PLANS. FLOOR CLEAN OUTS ETC.
		REVISE TO SHOW DIRECTION WHERE EXITING BUILDING.

Comments: