

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181846, Building Permit - Residential
Address: 1301 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Residential	Mark Harding	Failed	Thursday, August 02, 2018

Corrective Action Required

1	Misc	GARAGE PORTAL - 2 CAR GARAGE -NAILING OF PLYWOOD OK HOLD DOWN STRAPS NOT INSTALLED 3RD CAR GARAGE NOT BUILT SITTING IN THE FEILD. TOLD THEM TO RECALL WHEN WALLS WERE COMPLETE OK TO SIDE ABOVE THE STONE LINE ON THE 2CAR WALL ...
---	------	---

Comments: