

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181678, Building Permit - Residential

Address: 4430 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Jason McRoy	Passed	Friday, August 03, 2018

Gas Service Inspection - Residential	Jason McRoy	Passed	Friday, August 03, 2018
---	-------------	--------	-------------------------

Gas Piping Inspection - Residential	Jason McRoy	Passed	Friday, August 03, 2018
--	-------------	--------	-------------------------

All Rough Inspection - Residential	Jason McRoy	Failed	Friday, August 03, 2018
---	-------------	--------	-------------------------

Corrective Action Required

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">• fill all nail holes in straps at garage portal• Add snow blocking above garage and over master closet• Fire block notches at rim board in garage• Complete fire blocking above fire place• Over bored floor joist atfuter vent plumbing basement• Missing egress window basement• Over bored floor joist at plumbing left of stairs in basement• |
|---|------|---|

Comments: